

Name T.J. AmsteadDate 5-1-17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	3.50	3.77	.30	.007		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	1:38pm
Hwy 195 Tank	2.74	3.15	.46	.003		937950	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	24	1:56pm
CTWS Plant Line	.97	1.94	>.60	.007		495976	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	2:10pm
Ivy Mtn. Tank Meters	1.85	2.24	.57	.003		323688	705892	XXXXX	XXXXX	#17	XXXX	XXXX	92	12:50pm
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	112	XXXX	12:30pm
3362 Upton Dr.	1.45	1.70	.52	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	12:25pm
Donnell Tank/CC PS	1.31	1.48	.58	.006		3676718	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	10	42	22	12:01pm
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	58	58	XXXX	11:53pm
Stone Oaks	1.25	1.32	>.60	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	64	56	20	10:25pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	74	100	XXXX	11:00pm
CR 3420 Pump Sta.	.98	1.12	>.60	.003		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	62	90	XXXX	9:30pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	8	52	XXXXXX	8:50pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.01	1.08	>.60	.009		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	18	8:56pm
FM 580 Valve & Meter	1.11	1.25	>.60	.006		16347	rev. 0	556	XXXXX	#12	XXXX	XXXX	XXXX	8:40pm
Georgetown Tank And Pump Sta.	1.24	1.38	>.60	.003		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	24	56	/	8:23pm
Hwy 190 Valve & Meter	1.76	1.80	>.60	.005		28323	rev. 7006	1184	XXXXX	#11	XXXX	XXXX	XXXXXX	8:09pm
11986 E. Hwy 190 (Office)	1.08	1.21	>.60	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:48pm

RESET
TANK
PESRESET
METER

Name TJ AmsterdamDate 5-2-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.						XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Hwy 195 Tank						XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX		
CTWS Plant Line						XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Ivy Mtn. Tank Meters		2.65				325142	707674	XXXXX	XXXXX	#17	XXXX	XXXX	93	8:50am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	112	XXXX	8:35am
3362 Upton Dr.		1.95				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	8:27am
Donnell Tank/CC PS						XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#18				
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#20	56	52	XXXX	8:03am
Stone Oaks		1.44				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#22	62	56	18	11:18am
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#24	16	101	XXXX	10:51am
CR 3420 Pump Sta.		1.04				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#21	62	90	XXXX	10:46am
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	7	52	XXXXX	10:00am
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		1.16				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	16	10:04am
FM 580 Valve & Meter		1.09				642	rev. 0	119	XXXXX	#12	XXXX	XXXX	XXXX	9:53am
Georgetown Tank And Pump Sta.		1.43				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#14	20	52	✓	9:36am
Hwy 190 Valve & Meter		1.70				1090	rev. 203	536	XXXXX	#11	XXXX	XXXX	XXXXX	9:24am
11986 E. Hwy 190 (Office)		1.20				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:50am

Name TJ AmstedeDate 5-3-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	24.60	5.6	.20	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:12am
Hwy 195 Tank	3.54	3.98	.49	.004		946161	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	21	10:42am
CTWS Plant Line	1.61	2.60	>.60	.006		497529	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:37am
Ivy Mtn. Tank Meters	2.48	2.86	.47	.002		327261	710272	XXXXX	XXXXX	#17	XXXX	XXXX	93	9:19am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	116	XXXX	9:01am
3362 Upton Dr.	2.17	2.54	.48	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	8:56am
Donnell Tank/CC PS Cedar Creek Pump Sta.	.90	1.12	>.60	.010		3686470	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	12	46	18.5	11:38am
Stone Oaks	1.15	1.36	>.60	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	56	54	XXXX	8:31am
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	42	54	19	1:36pm
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
CR 3420 Pump Sta.	.70	.81	>.60	.014		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	72	100	XXXX	12:57pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	60	86	XXXX	2:01pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	8	50	XXXXX	2:27pm
Hewgley Tank # 1	.84	.96	>.60	.010		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	O/S	O/S	O/S	O/S
FM 580 Valve & Meter	1.20	1.38	>.60	.005		1497	rev. 0	-67	XXXXX	#15	XXXX	XXXX	20	2:35pm
Georgetown Tank And Pump Sta.	1.09	1.23	>.60	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#12	XXXX	XXXX	XXXX	2:47pm
Hwy 190 Valve & Meter	1.53	1.65	>.60	.009		2501	rev. 377	265	XXXXX	#14	20	52	—	3:06pm
11986 E. Hwy 190 (Office)	1.33	1.45	>.60	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#11	XXXX	XXXX	XXXXX	3:26pm
						XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:18am

Name TJ ANSTEADDate 5-4-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.						XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Hwy 195 Tank	3.37	3.81	.37	.002		949506	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	27	9:30 am
CTWS Plant Line	2.86	3.48	.60	.003		498952	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	9:40 am
Ivy Mtn. Tank Meters	2.85	3.20	.55	.002		329000	712402	XXXXX	XXXXX	#17	XXXX	XXXX	91	8:49 am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	118	XXXX	8:29 am
3362 Upton Dr.		2.73				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	8:17 am
Donnell Tank/CC PS		1.08				3689679	XXXXXXXXXXXXX	XXXXX	XXXXX	#18	20	50	20	10:14 am
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#20	58	56	XXXX	8:05 am
Stone Oaks		1.54				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#22	40	50	19	11:23
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#24	72	100	XXXX	11:37 am
CR 3420 Pump Sta.	.85	.98	>.60	.005		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#21	60	92	XXXX	12:10 pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	8	52	XXXXX	12:33 pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		.82				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	20	12:34 pm
FM 580 Valve & Meter		2.43				2021	Rev-6	120	XXXXX	#12	XXXX	XXXX	XXXX	12:48 pm
Georgetown Tank And Pump Sta.		1.52				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#14	21	60	—	
Hwy 190 Valve & Meter		2.09				3411	Rev-571	-577	XXXXX	#11	XXXX	XXXX	XXXXX	
11986 E. Hwy 190 (Office)		1.53				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:43 am

Name J.V. AmsterdamDate 5-5-17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	4.48	5.8	.25	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:26am
Hwy 195 Tank	3.86	4.11	.48	.004		952819	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	27	10:44am
CTWS Plant Line	2.52	3.04	>.60	.003		499678	XXXXXXXXXXXXXX	635 XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:55am
Ivy Mtn. Tank Meters	2.89	3.26	.54	.005		330657	714418	XXXXX	XXXXX	#17	XXXX	XXXX	95	9:16am
Ivy Gap Valve	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	116	XXXX	8:54am
3362 Upton Dr.	2.61	2.95	.56	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	8:47am
Donnell Tank/CC PS	1.10	1.26	.58	.006		3692991	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	12	42	20	8:32am
Cedar Creek Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	58	58	XXXX	11:27am
Stone Oaks	2.09	2.31	>.60	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	62	54	19	2:30pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	78	101	XXXX	2:56pm
CR 3420 Pump Sta.	1.06	1.18	>.60	.014		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	62	90	XXXX	1:54pm
Hewgley Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	10	50	XXXXX	1:22pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.00	1.12	>.60	.011		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX		1:28pm
FM 580 Valve & Meter	1.58	1.75	>.60	.008		2666	rev. 0	1179	XXXXX	#12	XXXX	XXXX	XXXX	1:05pm
Georgetown Tank And Pump Sta	1.20	1.47	>.60	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	22	50	—	12:36pm
Hwy 190 Valve & Meter	2.01	2.26	>.60	.004		4433	rev. 691	1084	XXXXX	#11	XXXX	XXXX	XXXXX	12:27pm
11986 E. Hwy 190 (Office)	1.69	1.83	.51	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:19am

Name

TANNER STEEL E

[illegible]

2d 62 mimosa Dr. pressure was fluctuating at 50
Changed PRV Gals, Set at 80. May 6th 2017 1hr

Name

Rodney Saur

Date

5/8/17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	4.11	4.57	0.20	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Hwy 195 Tank	3.50	3.94	0.48	.004		968985	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	22	
CTWS Plant Line	3.80	4.28	7.10	.005		503690	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Ivy Mtn. Tank Meters	2.84	3.21	0.48	.002		337308	722587	XXXXX	XXXXX	#17	XXXX	XXXX	92	
Ivy Gap Valve	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	115	XXXX	
3362 Upton Dr.	2.49	2.86	0.48	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	
Donnell Tank/CC PS	1.54	1.66	7.60	.011		3703265	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	12	45		
Cedar Creek Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	56	55	XXXX	
Stone Oaks	2.15	2.52	7.60	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	42	55	19	
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	70	100	XXXX	
CR 3420 Pump Sta.	2.22	2.52	7.60	0.13		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	45	85	XXXX	
Hewgley Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	B	52	XXXXX	
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.52	1.64	7.60	.010		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX		
FM 580 Valve & Meter	2.32	2.41	0.58	.003		2 Red	4838	177	XXXXX	#12	XXXX	XXXX	XXXX	
Georgetown Tank And Pump Sta.	2.17	2.28	7.60	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	20	54		
Hwy 190 Valve & Meter	3.98	5.99	7.60	.009		953 Red	6721	310	XXXXX	#11	XXXX	XXXX	XXXXX	
11986 E. Hwy 190 (Office)	2.13	2.30	7.60	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	

Name TJ AmsteadDate 5-9-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.		2.9				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:09am
Hwy 195 Tank		4.7				973520	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	19	10:35am
CTWS Plant Line		5.0				506491	XXXXXXXXXXXXXX	3140	XXXXX	#26	XXXX	XXXX	XXXX	10:40am
Ivy Mtn. Tank Meters		3.6				339218	724926	XXXXX	XXXXX	#17	XXXX	XXXX	100	9:30am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	116	XXXX	9:12am
3362 Upton Dr.		3.1				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	9:02am
Donnell Tank/CC PS		1.40				3706821	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	18	52	19	11:46am
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	58	58	XXXX	8:46am
Stone Oaks		2.4				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	62	56	19	1:07pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	78	101	XXXX	12:40pm
CR 3420 Pump Sta.		2.3				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	60	92	XXXX	1:55pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	10	52	XXXXXX	2:08pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		2.11				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	18	2:24pm
FM 580 Valve & Meter		2.5				5566	rev. 0	639	XXXXX	#12	XXXX	XXXX	XXXX	2:31pm
Georgetown Tank And Pump Sta.		2.3				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	22	52	✓	2:44pm
Hwy 190 Valve & Meter		2.6				8900	rev. 1042	1108	XXXXX	#11	XXXX	XXXX	XXXXXX	2:58pm
11986 E. Hwy 190 (Office)		2.2				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:08am

Name TJ AmstearDate 5-10-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	3.09	3.35	.31	.002		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	1:31pm
Hwy 195 Tank	>4.60	5.1	.44	.002		977871	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	25	1:58pm
CTWS Plant Line	>4.60	5.4	.33	.002		511538	XXXXXXXXXXXX	2658	XXXXX	#26	XXXX	XXXX	XXXX	1:46pm
Ivy Mtn. Tank Meters	3.69	3.86	.51	.002		341063	727200	XXXXX	XXXXX	#17	XXXX	XXXX	101	12:35pm
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	118	XXXX	12:18pm
3362 Upton Dr.	3.25	3.52	.55	.003		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	12:10pm
Donnell Tank/CC PS	1.50	1.59	>.60	.005		3710247	XXXXXXXXXXXX	XXXXX	XXXXX	#18	12	48	20	11:50pm
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#20	58	56	XXXX	11:21pm
Stone Oaks	2.33	2.49	>.60	.006		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#22	64	58	19	10:54pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#24	78	100	XXXX	10:26pm
CR 3420 Pump Sta.	2.11	2.23	.56	.005		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#21	62	98	XXXX	9:59pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	8	52	XXXXXX	9:28pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.45	1.53	>.60	.013		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	24	9:30pm
FM 580 Valve & Meter	2.24	2.27	.51	.003		5967	rev. 0	472	XXXXX	#12	XXXX	XXXX	XXXX	9:16pm
Georgetown Tank And Pump Sta	1.80	1.94	.56	.005		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#14	22	50	/	9:06pm
Hwy 190 Valve & Meter	2.39	2.56	.50	.002		9525	rev. 1248	1080	XXXXX	#11	XXXX	XXXX	XXXXXX	8:53pm
11986 E. Hwy 190 (Office)	2.17	2.30	.52	.003		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:21pm

Name TJ AmsteadDate 5-11-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.						XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Hwy 195 Tank							XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX		
CTWS Plant Line							XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Ivy Mtn. Tank Meters		3.98				343049	729623	XXXXX	XXXXX	#17	XXXX	XXXX	90	8:58 am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	8:45 am
3362 Upton Dr.		3.93				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	8:38 am
Donnell Tank/CC PS		1.84				3713131	XXXXXXXXXXXXX	XXXXX	XXXXX	#18	14	48	22	8:22 am
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#20	70	62	XXXX	8:02 am
Stone Oaks		2.35				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#22	42	55	18	9:42 am
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#24	78	101	XXXX	11:44 am
CR 3420 Pump Sta.		2.23				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#21	68	99	XXXX	10:15 am
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	18	46	XXXXXX	10:40 am
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		1.36				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	23	10:44 am
FM 580 Valve & Meter		2.62				6772	R-O	593	XXXXX	#12	XXXX	XXXX	XXXX	10:55 am
Georgetown Tank And Pump Sta.		1.78				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#14	28	51	—	11:10 am
Hwy 190 Valve & Meter		2.95				9523	R-1351	-10	XXXXX	#11	XXXX	XXXX	XXXXXX	11:20 am
11986 E. Hwy 190 (Office)		2.66				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:50 am

Name TS AMSTEADDate 5-12-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	85	1.96	.59	.017		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	1:58pm
Hwy 195 Tank	>4.60	5.2	.30	.001		986676	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	26	12:47pm
CTWS Plant Line	>4.60	5.9	.24	.002		519983	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	12:36pm
Ivy Mtn. Tank Meters	4.08	4.29	.36	.001		345134	732177	XXXXX	XXXXX	#17	XXXX	XXXX	92	11:58am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	118	XXXX	11:30am
3362 Upton Dr.	3.88	3.92	>.60	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	11:21am
Donnell Tank/CC PS	2.26	2.81	>.60	.006		3716147	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	10	50	21	2:29pm
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	62	58	XXXX	10:50am
Stone Oaks	2.48	2.61	>.60	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	64	58	20	10:26am
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	80	102	XXXX	10:00pm
CR 3420 Pump Sta.	2.18	2.33	.58	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	64	96	XXXX	9:40am
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	10	52	XXXXX	9:12am
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.39	1.51	>.60	.010		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	18	9:15am
FM 580 Valve & Meter	2.70	2.81	.54	.003		73005	rev. 0	1153	XXXXX	#12	XXXX	XXXX	XXXX	9:05am
Georgetown Tank And Pump Sta.	1.91	2.03	>.60	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	26	54	/	8:40am
Hwy 190 Valve & Meter	2.95	3.01	>.60	.003		11677	rev. 1514	778	XXXXX	#11	XXXX	XXXX	XXXXX	8:20am
11986 E. Hwy 190 (Office)	2.76	2.89	.59	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:59pm

Name Jacob Syx

[illegible]

Name C. MickDate 15 May 17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	2.10	2.12	2.60	.001	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	0948
Hwy 195 Tank	3.82	4.25	.19	.001	/	000785	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	23	1002
CTWS Plant Line	4.88 4.60	4.60	.16	.001	/	534357	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	1042
Ivy Mtn. Tank Meters	3.54	3.76	.31	.000	/	351321	739551	XXXXX	XXXXX	#17	XXXX	XXXX	90	0822
Ivy Gap Valve	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	0901
3362 Upton Dr.	3.53	3.74	.48	.002	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	0905
Donnell Tank/CC PS	2.34	2.34	2.60	.003	/	3726862	XXXXXXXXXXXX	XXXXX	XXXXX	#18	10	44	24	0844
Cedar Creek Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#20	60	60	XXXX	852
Stone Oaks	3.64	3.62	2.60	.002	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#22	64	48	19	1102
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#24	85	100	XXXX	1135
CR 3420 Pump Sta.	2.98	3.13	.53	.002	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#21	70	95	XXXX	1249
Hewgley Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	6	50	XXXXX	1302
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.91	1.95	2.60	.011	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	25	1309
FM 580 Valve & Meter	3.53	3.59	.60	.009	/	9458	0	1228	XXXXX	#12	XXXX	XXXX	XXXX	1319
Georgetown Tank And Pump Sta.	2.81	2.95	2.60	.011	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#14	27	52	/	1337
Hwy 190 Valve & Meter	3.62	3.58	.59	.001	/	13331	1947	1399	XXXXX	#11	XXXX	XXXX	XXXXX	1355
11986 E. Hwy 190 (Office)	3.32	3.37	.38	.002	/	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	1418

Name TJ AmsteadDate 5-16-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.		5.1				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:40am
Hwy 195 Tank		2.4				005597	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	24	10:05am
CTWS Plant Line		3.8				536058	XXXXXXXXXXXXXX	0	XXXXX	#26	XXXX	XXXX	XXXX	10:26am
Ivy Mtn. Tank Meters		2.9				353594	742261	XXXXX	XXXXX	#17	XXXX	XXXX	77	9:26am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	122	XXXX	9:49am
3362 Upton Dr.		3.8				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXX	8:53am
Donnell Tank/CC PS		2.5				3730218	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	12	46	20	11:26am
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	62	60	XXXX	8:41am
Stone Oaks		3.1				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	64	56	20	12:38pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	80	101	XXXX	12:05pm
CR 3420 Pump Sta.		2.8				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	68	90	XXXX	1:23pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	8	50	XXXX	1:50pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		2.08				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	22	1:55pm
FM 580 Valve & Meter		2.9				10165	rev. 0	566	XXXXX	#12	XXXX	XXXX	XXXX	2:10pm
Georgetown Tank And Pump Sta.		2.3				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	24	56	✓	2:55pm
Hwy 190 Valve & Meter		3.0				16515	rev. 2072	1438	XXXXX	#11	XXXX	XXXX	XXXX	2:52pm
11986 E. Hwy 190 (Office)		2.8				XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:01am

Name

T J Amstead

Date

5-17-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	>4.60	6.5	.23	.002		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#26	xxxx	xxxx	xxxx	10:07am
Hwy 195 Tank	>4.60	5.3	.35	.003		10225	xxxxxxxxxxxx	xxxxx	xxxxx	#26	xxxx	xxxx	84	10:28am
CTWS Plant Line	4.06	4.23	.29	.001		536156	xxxxxxxxxxxx	0	xxxxx	#26	xxxx	xxxx	xxxx	10:49a
Ivy Mtn. Tank Meters	2.42	2.58	.33	.001		355787	744843	xxxxx	xxxxx	#17	xxxx	xxxx	92	9:26am
Ivy Gap Valve	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#16	xxxx	118	xxxx	9:08am
3362 Upton Dr.	2.26	2.32	.40	.002		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#9	xxxx	xxxx	xxxxx	9:02am
Donnell Tank/CC PS Cedar Creek Pump Sta.	2.51	2.59	.46	.003		3733628	xxxxxxxxxxxx	xxxxx	xxxxx	#18	14	46	82	11:42am
Stone Oaks	2.64	2.76	.50	.004		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#22	62	56	18	1:11pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#13	xxxx	xxxx	O/S	O/S
Northeast Pump Sta.	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#24	72	100	xxxx	12:41pm
CR 3420 Pump Sta.	2.43	2.52	>.60	.006		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#21	68	92	xxxx	1:54pm
Hewgley Pump Sta.	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#15	10	52	xxxxx	2:18pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	2.25	2.31	>.60	.008		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#15	xxxx	xxxx	24	2:24pm
FM 580 Valve & Meter	2.71	2.84	.54	.005		10735	rev. 0	0	xxxxx	#12	xxxx	xxxx	xxxx	2:46pm
Georgetown Tank And Pump Sta.	2.30	2.46	>.60	.007		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#14	24	54		2:51pm
Hwy 190 Valve & Meter	3.11	3.38	>.60	.005		17495	rev. 2368	-528	xxxxx	#11	xxxx	xxxx	xxxxx	3:12pm
11986 E. Hwy 190 (Office)	2.33	2.35	.46	.002		xxxxxxxxxxxx	xxxxxxxxxxxx	xxxxx	xxxxx	#1	xxxx	xxxx	xxxx	8:06am

Name E. J. AMSENDate 5-18-17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.						XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Hwy 195 Tank							XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX		
CTWS Plant Line							XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	
Ivy Mtn. Tank Meters		4.46				356910	746202	XXXXX	XXXXX	#17	XXXX	XXXX	43	9:08am
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	1160	XXXX	8:45am
3362 Upton Dr.		2.61				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	8:39am
Donnell Tank/CC PS		2.56				3736938	XXXXXXXXXXXX	XXXXX	XXXXX	#18	10	44	21	10:01am
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#20	58	56	XXXX	8:14am
Stone Oaks		3.01				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#22	42	58	18	11:40am
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#24	76	100	XXXX	11:14am
CR 3420 Pump Sta.		2.14				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#21	68	92	XXXX	12:18pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	8	50	XXXXX	12:42pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		1.96				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	20	12:46pm
FM 580 Valve & Meter		2.26				11312	rev. 0	127	XXXXX	#12	XXXX	XXXX	XXXX	12:58pm
Georgetown Tank And Pump Sta.		2.02				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#14	22	50	/	1:16pm
Hwy 190 Valve & Meter		2.66				18534	rev. 2571	-543	XXXXX	#11	XXXX	XXXX	XXXXX	1:28pm
11986 E. Hwy 190 (Office)		1.82				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:51pm

Name 1 JAMSTEADDate 5-19-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	24.60	5.0	.17	.001		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#20	XXXX	XXXX	XXXX	10:19am
Hwy 195 Tank	4.52	4.9	.35	.002		18391	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	26	10:58am
CTWS Plant Line	3.13	3.13	>.60	.001		536156	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:42am
Ivy Mtn. Tank Meters	4.56	4.7	.39	.002		358556	748161	XXXXX	XXXXX	#17	XXXX	XXXX	101	9:40am
Ivy Gap Valve	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	118	XXXX	9:24am
3362 Upton Dr.	4.38	4.6	.45	.003		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	9:17am
Donnell Tank/CC PS	3.31	3.49	.48	.004		3740212	XXXXXXXXXXXXX	XXXXX	XXXXX	#18	12	46	20	12:25pm
Cedar Creek Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#20	56	56	XXXX	8:30am
Stone Oaks	3.51	3.58	.56	.002		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#22	62	58	20	1:42pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#24	74	100	XXXX	1:13pm
CR 3420 Pump Sta.	2.19	2.27	>.60	.008		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#21	66	94	XXXX	2:12pm
Hewgley Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	7	52	XXXXX	2:30pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.89	2.08	.58	.007		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	24	2:38pm
FM 580 Valve & Meter	2.95	2.94	.53	.003		11919	rev. 0	618	XXXXX	#12	XXXX	XXXX	XXXX	2:54pm
Georgetown Tank And Pump Sta.	2.31	2.34	.58	.006		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#14	22	50	✓	3:12pm
Hwy 190 Valve & Meter	3.59	3.66	.53	.002		19594	rev. 2775	1404	XXXXX	#11	XXXX	XXXX	XXXXX	3:26pm
11986 E. Hwy 190 (Office)	3.14	3.32	.55	.006		XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:57am

Name C. Mick

Holiday		DATE	20 May 2017			
LOCATION	FREE	TOTAL	N. Readings	S. Readings	SITE	Condition/Solition
Ivy Mountain	xxxxxx	3.79	360001	749881	#17	
3362 Upton Dr.	xxxxxx	3.27	XXXXXXXX	XXXXXXXX	#9	
KWSC Office	xxxxxx	2.89	XXXXXXXX	XXXXXXXX	#1	
Hwy 190 Meter	xxxxxx	3.63	20237	3032 ¹⁵²⁰	#11	
FM 580 Meter	xxxxxx	2.51	12280	0 ⁵⁸⁴	#12	
Hewgley Tank #1	xxxxxx	1.91	XXXXXXXX	XXXXXXXX	#15-1	
Holiday		DATE	21 May 2017			
Ivy Mountain	xxxxxx	2.78 ^{ccm}	361292	751416	#17	3.68 total
3362 Upton Dr.	xxxxxx	3.38	XXXXXXXX	XXXXXXXX	#9	
KWSC Office	xxxxxx	2.90	XXXXXXXX	XXXXXXXX	#1	
Hwy 190 Meter	xxxxxx	3.41 ^{JW}	21135	3379 ⁷⁶⁰	#11	
FM 580 Meter	xxxxxx	3.85	12766	0 ⁻¹⁸⁸	#12	

Name Rodney SeawerDate 5/22/17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	1.34	1.35	70.60	.052		xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#26	xxxx	xxxx	xxxx	
Hwy 195 Tank	4.48	4.43	0.39	.002		26804	xxxxxxxxxxxxx	xxxxx	xxxxx	#26	xxxx	xxxx	30	
CTWS Plant Line	3.08	3.07	70.60	.002		536156	xxxxxxxxxxxxx	xxxxx	xxxxx	#26	xxxx	xxxx	xxxx	
Ivy Mtn. Tank Meters	4.29	4.25	0.45	.002		362803	753287	xxxxx	xxxxx	#17	xxxx	xxxx	105	
Ivy Gap Valve	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#16	xxxx	118	xxxx	
3362 Upton Dr.	Skipped					xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#9	xxxx	xxxx	xxxxx	
Donnell Tank/CC PS Cedar Creek Pump Sta.	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#18				
Stone Oaks	3.33	3.32	0.58	.002		xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#22	64	58	19	
Northeast Tank	O/S	O/S	O/S	O/S	O/S	xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#13	xxxx	xxxx	O/S	O/S
Northeast Pump Sta.	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#24	70	90	xxxx	
CR 3420 Pump Sta.	3.34	3.33	7.60	.002		xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#21	71	95	xxxx	
Hewgley Pump Sta.	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxx	xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#15	8	50	xxxxx	
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.91	1.89	0.58	.007		xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#15	xxxx	xxxx	22	
FM 580 Valve & Meter	2.92	2.84	0.57	.004		Q Rev	13331	184	xxxxx	#12	xxxx	xxxx	xxxx	
Georgetown Tank And Pump Sta.	2.35	2.37	0.59	.006		xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#14	20	52		
Hwy 190 Valve & Meter	3.04	3.05	0.59	.002		3725 Rev	22244	1585	xxxxx	#11	xxxx	xxxx	xxxxx	
11986 E. Hwy 190 (Office)	3.38	3.39	0.52	.021		xxxxxxxxxxxxx	xxxxxxxxxxxxx	xxxxx	xxxxx	#1	xxxx	xxxx	xxxx	

Flow

Name JS AmsteadDate 5-23-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	>4.60	4.9	.33	.004		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:21am
Hwy 195 Tank		4.21				30094	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	25	10:38am
CTWS Plant Line		2.96				536156	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:44am
Ivy Mtn. Tank Meters		4.00				364316	755018	XXXXX	XXXXX	#17	XXXX	XXXX	43	9:40am
Ivy Gap Valve	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	9:17am
3362 Upton Dr.	4.13	3.97	.42	.004		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	9:10am
Donnell Tank/CC PS	2.96	2.92	>.60	.005		3753477	XXXXXXXXXXXX	XXXXX	XXXXX	#18	10	44	22	11:40am
Cedar Creek Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#20	60	58	XXXX	8:46am
Stone Oaks	3.51	3.56	.55	.002		XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#22	62	56	18	1:35pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#24	78	100	XXXX	12:45pm
CR 3420 Pump Sta.		3.46				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#21	70	90	XXXX	2:14pm
Hewgley Pump Sta.	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	10	52	XXXXX	2:35pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		2.11				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	24	2:38pm
FM 580 Valve & Meter		3.16				13854	rev. 0	1162	XXXXX	#12	XXXX	XXXX	XXXX	2:50pm
Georgetown Tank And Pump Sta.		2.49				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#14	24	56	/	3:02pm
Hwy 190 Valve & Meter		3.71				23188	rev. 4015	1261	XXXXX	#11	XXXX	XXXX	XXXXX	3:20pm
11986 E. Hwy 190 (Office)		3.44				XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:11am

Name T J AmsteadDate 5-24-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	>4.60	4.7	.37	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:10am
Hwy 195 Tank	4.31	4.38	.40	.003		33398	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	26	10:28am
CTWS Plant Line	2.96	3.05	.52	.006		536156	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:39am
Ivy Mtn. Tank Meters	3.90	3.94	.39	.002		365746	756696	XXXXX	XXXXX	#17	XXXX	XXXX	95	9:18am
Ivy Gap Valve	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	118	XXXX	8:50am
3362 Upton Dr.	3.79	3.88	.48	.003		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	8:42am
Donnell Tank/CC PS Cedar Creek Pump Sta.	3.19	3.23	.56	.005		3756733	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	12	40	21	11:21am
Stone Oaks	3.24	3.23	.53	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	60	50	18	12:56pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	74	100	XXXX	12:13pm
CR 3420 Pump Sta.	3.49	3.51	>.60	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	70	92	XXXX	1:32pm
Hewgley Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	8	50	XXXXX	2:03pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	2.16	2.17	>.60	.015		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	22	2:11pm
FM 580 Valve & Meter	2.93	2.94	>.60	.008		14402	rev. 0	89	XXXXX	#12	XXXX	XXXX	XXXX	2:33pm
Georgetown Tank And Pump Sta.	2.46	2.51	>.60	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	22	50	/	2:50pm
Hwy 190 Valve & Meter	3.55	3.71	>.60	.004		24155	rev. 4278-347	XXXXX	XXXXX	#11	XXXX	XXXX	XXXXX	3:08pm
11986 E. Hwy 190 (Office)	3.29	3.32	.39	.009		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:11am

Name TJ AmstedDate 5-25-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.		3.8			2.1	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:02am
Hwy 195 Tank		3.9			2.3	36066	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	27	10:36am
CTWS Plant Line		3.0			1.8	536156	XXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:24am
Ivy Mtn. Tank Meters		3.9			2.1	366869	758057	XXXXX	XXXXX	#17	XXXX	XXXX	101	9:16am
Ivy Gap Valve	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	8:51am
3362 Upton Dr.		3.7			2.0	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXX	8:37am
Donnell Tank/CC PS Cedar Creek Pump Sta.		2.8			1.9	3760076	XXXXXXXXXXXX	XXXXX	XXXXX	#18	10	46	22	11:14am
	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#20	60	60	XXXX	8:16am
Stone Oaks		3.4			1.6	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#22	42	54	18	12:57pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#24	78	105	XXXX	12:12pm
CR 3420 Pump Sta.		2.6			1.8	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#21	72	92	XXXX	10:39am
Hewgley Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	7	52	XXXX	2:01pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		2.3			1.7	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	22	2:08pm
FM 580 Valve & Meter		3.1			1.8	14997	rev. 0	62	XXXXX	#12	XXXX	XXXX	XXXX	2:24pm
Georgetown Tank And Pump Sta.		2.6			1.6	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#14	24	50	/	2:43pm
Hwy 190 Valve & Meter		3.0			1.8	25221	rev. 4505	-579	XXXXX	#11	XXXX	XXXX	XXXX	2:59pm
11986 E. Hwy 190 (Office)		3.1			1.9	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:57am

Name J.J. AmsterDate 5-26-17

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	.64	.77	.05	.001		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:00am
Hwy 195 Tank	3.10	3.13	.25	.002		39016	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	22	10:39am
CTWS Plant Line	2.80	2.81	.59	.002		536783	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:56am
Ivy Mtn. Tank Meters	3.36	3.33	.35	.002		368563	760075	XXXXX	XXXXX	#17	XXXX	XXXX	98	9:13am
Ivy Gap Valve	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	8:51am
3362 Upton Dr.	3.51	3.50	.45	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXXX	8:40am
Donnell Tank/CC PS	2.80	2.83	.54	.003		3763384	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	10	44	21	11:33am
Cedar Creek Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	58	56	XXXX	8:16am
Stone Oaks	2.86	2.90	.50	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	42	50	17	12:48pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	78	100	XXXX	12:23pm
CR 3420 Pump Sta.	2.94	2.93	.58	.002		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	64	96	XXXX	1:23pm
Hewgley Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	7	50	XXXXX	2:03pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.83	1.90	.57	.010		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	24	2:11pm
FM 580 Valve & Meter	2.21	2.23	>.60	.006		15516	rev. 0	180	XXXXX	#12	XXXX	XXXX	XXXX	2:30pm
Georgetown Tank And Pump Sta.	1.79	1.87	>.60	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	24	50	/	2:47pm
Hwy 190 Valve & Meter	3.01	3.07	.54	.003		26131	rev. 4772	323	XXXXX	#11	XXXX	XXXX	XXXXX	3:01pm
11986 E. Hwy 190 (Office)	2.73	2.70	.55	.011		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	7:57am

Live Oak Cem. Flushed 3000 gals To get Residual
 CR3420 Changed 3/8 ball valve pump # 2

Name Tanner Steele

Holiday		DATE	5-29-2017			
LOCATION	FREE	TOTAL	N. Readings	S. Readings	SITE	Condition/Solition
Ivy Mountain	xxxxxx	3.4	373089	765466	#17	
3362 Upton Dr.	xxxxxx	3.1	XXXXXXXX	XXXXXXXX	#9	
KWSC Office	xxxxxx	2.0	XXXXXXXX	XXXXXXXX	#1	
Hwy 190 Meter	xxxxxx	3.5	28782	5654	#11	
FM 580 Meter	xxxxxx	3.1	16900	0	#12	
Hewgley Tank #1	xxxxxx	2.0	XXXXXXXX	XXXXXXXX	#15-1	
Holiday		DATE				
Ivy Mountain	xxxxxx				#17	
3362 Upton Dr.	xxxxxx		XXXXXXXX	XXXXXXXX	#9	
KWSC Office	xxxxxx		XXXXXXXX	XXXXXXXX	#1	
Hwy 190 Meter	xxxxxx				#11	
FM 580 Meter	xxxxxx				#12	

Name TJ AmsteadDate 5-30-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.	3.67	3.87	.08	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:19am
Hwy 195 Tank	2.90	2.92	.17	.001		53539	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	26	10:42am
CTWS Plant Line	1.42	1.42	.47	.006		537785	XXXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:55am
Ivy Mtn. Tank Meters	3.04	3.02	.25	.004		374616	767283	XXXXX	XXXXX	#17	XXXX	XXXX	98	9:20am
Ivy Gap Valve	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	8:56am
3362 Upton Dr.	3.15	3.16	.37	.005		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	8:52am
Donnell Tank/CC PS	2.54	2.49	.49	.009		3776271	XXXXXXXXXXXXXX	XXXXX	XXXXX	#18	26	54	22	12:16pm
Cedar Creek Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#20	62	60	XXXX	8:28am
Stone Oaks	2.70	2.73	.52	.006		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#22	42	58	19	2:00pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#24	78	101	XXXX	1:22pm
CR 3420 Pump Sta.	1.82	1.84	.54	.009		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#21	62	94	XXXX	2:36pm
Hewgley Pump Sta.	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	8	52	XXXXX	2:56pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1	1.85	1.91	.50	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	24	3:00pm
FM 580 Valve & Meter	2.53	2.55	.52	.006		17598	rev. 0	1017	XXXXX	#12	XXXX	XXXX	XXXX	3:16pm
Georgetown Tank And Pump Sta	2.10	2.18	.58	.008		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#14	24	52	/	3:28pm
Hwy 190 Valve & Meter	3.11	3.19	.54	.006		30009	rev. 5985	742	XXXXX	#11	XXXX	XXXX	XXXXX	3:41pm
11986 E. Hwy 190 (Office)	3.08	3.07	.43	.004		XXXXXXXXXXXXXX	XXXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:02am

Name

J J Hamstead

Date

5-31-2017

Rotation	M/W/F	Daily	M/W/F	M/W/F	25th	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily	Daily
LOCATION	MONO CL2	TOTAL CL2	FREE Ammon	Nitrite NO3	Nitrate	Forward N. READINGS	Reverse S. READINGS	N. FLOW	S. FLOW	SITES	IN Psi	Out Psi	Tank Level	Time
WTP Live Oak Cem.		3.4				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	10:10am
Hwy 195 Tank		3.0				57047	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	22	9:50A
CTWS Plant Line		.93				537785	XXXXXXXXXXXXX	XXXXX	XXXXX	#26	XXXX	XXXX	XXXX	9:55am
Ivy Mtn. Tank Meters		2.8				376337	769335	XXXXX	XXXXX	#17	XXXX	XXXX	100	8:51pm
Ivy Gap Valve	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#16	XXXX	120	XXXX	8:29pm
3362 Upton Dr.		2.9				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#9	XXXX	XXXX	XXXXX	8:18am
Donnell Tank/CC PS		2.3				3779581	XXXXXXXXXXXXX	XXXXX	XXXXX	#18	16	48	21	11:35am
Cedar Creek Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#20	64	60	XXXX	8:09pm
Stone Oaks		2.3				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#22	60	56	20	8:05pm
Northeast Tank	O/S	O/S	O/S	O/S	O/S	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#13	XXXX	XXXX	O/S	O/S
Northeast Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#24	76	101	XXXX	3:25pm
CR 3420 Pump Sta.		1.93				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#21	64	40	XXXX	1:12pm
Hewgley Pump Sta.	XXXXXXXX	XXXXXXXX	XXXXXXXX	XXXXXX	XXXXXX	XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	8	50	XXXXX	12:35pm
Hewgley Tank # 2	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	O/S	#15	O/S	O/S	O/S	O/S
Hewgley Tank # 1		2.09				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#15	XXXX	XXXX	26	12:48pm
FM 580 Valve & Meter		2.7				18031	0		XXXXX	#12	XXXX	XXXX	XXXX	12:23pm
Georgetown Tank And Pump Sta.		1.86				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#14	24	58	12:09pm	
Hwy 190 Valve & Meter		3.0				30745	-6121		XXXXX	#11	XXXX	XXXX	XXXXX	12:01pm
11986 E. Hwy 190 (Office)		2.4				XXXXXXXXXXXXX	XXXXXXXXXXXXX	XXXXX	XXXXX	#1	XXXX	XXXX	XXXX	8:00pm